

## **Key Performance Indicators ...**

**Air Quality, Energy, Water, Light, Lifts, Internet, People.**

**March, 2017**

## Indochine Engineering

Leading multi-discipline engineering consultancy (MEP/C&S) in South East Asia





Recognized provider of 'good engineering' services to 'good teams' achieving great projects.

Strong team of multi-discipline engineers with a reputation for high quality & sustainable assets.

We wish to be involved with great teams on great projects for good clients, who recognise value in high quality assets.



We wish to be involved with buildings that work well.

So what are the Key Performance Indicators to identify that ...



# Air Quality

- Overview AQI



Source: <http://aqicn.org/city/vietnam/ho-chi-minh-city/us-consulate/>


# Air Quality

$$I_p = [(I_{hi} - I_{low}) / (BP_{hi} - BP_{low})] (C_p - BP_{low}) + I_{low}$$

- The AQI is an index for reporting daily air quality, runs from 0 to 500.
- The purpose of the AQI is to help you understand what local air quality means to your health.
- The higher the AQI value, the greater the level of air pollution and the greater the health concern.

Air Quality Index Levels of Health Concern	Numerical Value	Meaning
Good	0 to 50	Air quality is considered satisfactory, and air pollution poses little or no risk.
Moderate	51 to 100	Air quality is acceptable; however, for some pollutants there may be a moderate health concern for a very small number of people who are unusually sensitive to air pollution.
Unhealthy for Sensitive Groups	101 to 150	Members of sensitive groups may experience health effects. The general public is not likely to be affected.
Unhealthy	151 to 200	Everyone may begin to experience health effects; members of sensitive groups may experience more serious health effects.
Very Unhealthy	201 to 300	Health alert: everyone may experience more serious health effects.
Hazardous	301 to 500	Health warnings of emergency conditions. The entire population is more likely to be affected.

### AQI Calculator: Concentration to AQI



Select a criteria pollutant and enter the pollutant concentration in the specified units above; the Air Quality Index and associated information are calculated below.

Select a Pollutant

Units Required:


Enter the Concentration:

AQI:  AQI Category:

Sensitive Groups	Health Effects Statements	Cautionary Statements
People with respiratory or heart disease, the elderly and children are the groups most at risk.	Unusually sensitive people should consider reducing prolonged or heavy exertion.	Unusually sensitive people should consider reducing prolonged or heavy exertion.

# Air Quality

- Central air system with heat wheel and filtration



## Recirculating air system



[Learn More »](#)

## Air Quality


Minimum Efficiency Reporting Value (MERV) is a standard that rates the overall effectiveness of air filters. Higher value MERV rating equates to finer filtration, meaning fewer dust particles and other airborne contaminants can pass through the filter.

<b>Filter Comparisons (non-HEPA)</b>				
These comparisons of filter rating systems are only approximate as the test methods are different.				
<b>ASHRAE 52.2</b>	<b>ASHRAE 52.1</b>		<b>EU type</b>	<b>EN 779</b>
<b>MERV Designation</b>	<b>Arrestance</b>	<b>Dust Spot</b>	<b>Designation</b>	<b>Designation</b>
1	<65%	<20%	EU 1	G 1
2	65-70%	<20%	EU 2	G 2
3	70-75%	<20%	EU 2	G 2
4	70-80%	<20%	EU 2	G 2
5	80-85%	<20%	EU 3	G 3
6	85-90%	<20%	EU 4	G 4
7	>90%	25-30%	EU 4	G 4
8	>90%	30-35%	EU 5	F 5
9	>90%	40-45%	EU 5	F 5
10	>95%	50-55%	EU 5	F 5
11	>95%	60-65%	EU 6	F 6
12	>95%	70-75%	EU 6	F 6
13	>98%	80-90%	EU 7	F 7
14	>98%	90-95%	EU 8	F 8
15	99+%	>95%	EU 9	F 9
16	99+%	>95%	EU 9	F 9
				<b>EN 1822 *</b>
16	99+%	>95%	EU 10	H10

\* All EN 1822 tests at [MPPS](#) H = HEPA; U = ULPA

# Air Quality


## Filter MERV16/ EU9



# Air Quality

- Performance in ICE office and RMIT Hanoi

## ICE OFFICE



### AQI Calculator: Concentration to AQI

Select a criteria pollutant and enter the pollutant concentration in the specified units above, the Air Quality Index and associated information are calculated below.

Select a Pollutant


Units Required:

Enter the Concentration:

AQI:  AQI Category: Moderate

Sensitive Groups	Health Effects Statements	Cautionary Statements
People with respiratory or heart disease, the elderly and children are the groups most at risk.	Unusually sensitive people should consider reducing prolonged or heavy exertion.	Unusually sensitive people should consider reducing prolonged or heavy exertion.

## RMIT Hanoi



### AQI Calculator: Concentration to AQI

Select a criteria pollutant and enter the pollutant concentration in the specified units above, the Air Quality Index and associated information are calculated below.

Select a Pollutant

Units Required:

Enter the Concentration:


AQI:  AQI Category: Moderate

Sensitive Groups	Health Effects Statements	Cautionary Statements
People with respiratory or heart disease, the elderly and children are the groups most at risk.	Unusually sensitive people should consider reducing prolonged or heavy exertion.	Unusually sensitive people should consider reducing prolonged or heavy exertion.



## Air Quality KPI

- Have sufficient outside (fresh air) air for dilution of indoor air contaminants (CO<sub>2</sub>, dust, VOCs, odors)
- Centralise air handling plant (PAUs)
- Utilise heat recovery for energy management
- Modulate outside air based upon CO<sub>2</sub>
- Filter outside air G3 + EU7 or EU9 (equivalent to Merv 16)
- Target KPI AQI 50 to 100 for standard building and < 50 for leading standard.



The screenshot shows the AirNow website interface. At the top left is the AirNow logo. To the right is a search bar with a 'Go' button. Below the logo is a section for 'Local Air Quality Conditions' with input fields for 'Zip Code:' and 'State: Alabama' (with a dropdown arrow), and 'Go' buttons. A 'My Current Location' link is also present. The main heading is 'Air Quality Index (AQI) Basics'. Below this is a link for 'Versión en Español'. The AQI logo is displayed, followed by a paragraph explaining the AQI: 'The AQI is an index for reporting daily air quality. It tells you how clean or polluted your air is, and what associated health effects might be a concern for you. The AQI focuses on health effects you may experience within a few hours or days after breathing polluted air. EPA calculates the AQI for five major air pollutants regulated by the Clean Air Act: ground-level ozone, particle pollution (also known as particulate matter), carbon monoxide, sulfur dioxide, and nitrogen dioxide. For each of these pollutants, EPA has established national air quality standards to protect public health. Ground-level ozone and airborne particles are the two pollutants that pose the greatest threat to human health in this country.'

**Publications**

- [Air Quality Index - A Guide to Air Quality and Your Health](#)
- [Air Quality Guide for Ozone](#)
- [Air Quality Guide for Particle Pollution](#)

## Typical Energy Baselines

Building Type	Building prototype	Energy use intensity [ kWh / sqm-yr ]	Energy use intensity [ MJ / sqm-yr ]
Office	Small office	103	372
	Medium office	117	421
	Large Office	105	378
Retail	Stand-Alone Retail	151	545
	Strip Mall	179	646
Education	Primary School	151	545
	Secondary school	126	452
Healthcare	Outpatient healthcare	396	1,424
	Hospital	373	1,341
Lodging	Small Hotel	210	756
	Large Hotel	441	1,588
Warehouse	Non-refrigerated	61	218
Food service	Fast-food Restaurant	1,640	5,904
	Sit-Down Restaurant	1,044	3,758
Apartment	Mid-rise Apartment	130	468
	High-rise Apartment	129	466



Source: ASHRAE Standard 90.1-2010 Final Determination Quantitative Analysis

# Energy Calculation

General info Space summary Advisory messages Proposed vs baseline Energy type summary On site renewables  
 Exceptional calc measure Report


INTEGRATED ENVIRONMENTAL SOLUTIONS LTD **IES**

## 1.1 General information




 Building Form	<b>Responsible individual:</b> Xuyen Le <b>Company name:</b> ICE <b>Simulation program:</b> Integrated Environmental Solutions Virtual Environment version 2015 <b>Energy Code:</b> ASHRAE 90.1 - 2007 Appendix G <b>Model data:</b> Project file: A102 - GH.mlt Model floor area <sup>1</sup> : 51522.86 m <sup>2</sup> Building floor area <sup>2</sup> : 30054.03 m <sup>2</sup> Building volume <sup>3</sup> : 125799.47 m <sup>3</sup> Number of conditioned rooms: 278 No of floors: 30	This report produces output in accordance with the LEE NC 2009 Submittal Template, 2007 - option 1: Performance Rating Method. The Virtual Environment software has all the capabilities described in Q2 Simulation General Requirements in Appendix G of ASHRAE 90.1 - 2007. The baseline building and proposed building in this project's energy simulation use the assumptions and modelling methodology described in Appendix G of ASHRAE 90.1 - 2007. The report outputs that sequence with the following 90 sections: 1.1 - General info 1.2 - Space Summary 1.3 - Advisory messages 1.4 - Comparison of proposed design versus baseline design energy model inputs 1.5 - Energy type summary 1.6 - On site renewable energy (if applicable) 1.7 - Exceptional calculation measure summary (if applicable) 1.8 - Performance rating method compliance report
	<b>Heating calculation data:</b> Principal heating source: Electricity Results file: A102 - GH.hg Calculated: 07/Dec/2015 17:18	1. 'Model floor area' is the total floor area of all rooms in the building regardless of whether they are conditioned. 2. 'Building floor area' is the total area of all rooms for which 'include in building floor area' is ticked in 'Room Data' (used for loads metrics in this report). 3. 'Building volume' is the total volume of all rooms for which 'include in building floor area' is ticked in 'Room Data'.
	<b>Cooling calculation data:</b> Principal cooling source: Electricity Results file: A102 - GH.cdg Calculated: 07/Dec/2015 17:19	
 Building Form	<b>Design weather:</b> Source: ASHRAE design weather database Weather location: Tan Son Hoa, Vietnam Weather file: HCM_Q1 <b>Climate zone:</b> ASHRAE 90.1: 1A Koepfen-Geiger: Aw	
 Building Form	<b>Construction:</b> New construction %: 100 Existing construction %: 0	

## Annual Component Energy

Category	Internal Lighting	Exterior Lighting	Space Cooling	Pumps	Heat Rejection	Fans Interior	Fans Parking Garage	Receptacle Equipment	Total
kWh	968,827	189,442	1,186,115	24,084	432,813	416,810	252,505	1,856,592	<b>5,327,188</b>



# Energy Calculation




## Ventilation – Heat recovery

### Function

Transfers heat and humidity from incoming fresh air to outgoing exhaust air.

### Savings

- Add 3% energy saving
- Payback in 0 years



# High Efficiency Cooling

## Function

Provides cooling with minimal energy use by employing the correct cooling system. Oversized equipment is very common in hot climates.

## Benefits


- Equipment spends most of the operation time within most efficient operating ranges.
- Reduced operation costs.

## Drawbacks

- Higher level of maintenance may be required on larger projects.

## Savings

- Adequately sizing equipment, especially chillers reduces energy consumption.
- Oversized equipment can use up to 30% more energy than adequately sized equipment.



# Pump and AHU Control

## Function

Ensures all pumps and AHU operate efficiently during part-load use.

## Benefits


- Significantly reduces pumping and AHU energy.
- Significantly improves part-load performance of all building service systems.
- Improves occupant comfort and process performance.

## Drawbacks

- Capital cost, based on the size of the AHU/pump motors.

## Savings

- Payback is less than 1 year for large motors, up to 3 years for smaller motors.



# BMS

## Function

Controls lighting, air conditioning, media, telecoms, security, and other aspects of floors and similar spaces.

## Benefits

- Reduced wasted energy associated with bad habits and operating empty rooms.

## Drawbacks

- Maintenance competency required.

## Savings

- Additional savings can be achieved with more advanced systems.
- Payback from 1-5 years.



Smart Services on BeOPT™ Platform




For Energy & Facility Management



# Energy KPI

- Start with an economical design ....
- Manage solar and thermal loads
- Monitor and control outside (fresh) air
- High efficiency plant
- Efficient system integration
- Modern building management system
- Test & commission to verify
- Energy KPI – 30% below baseline ... or nominally 150 to 170 kWh/m<sup>2</sup>/annum (office) ... US\$2.00/m<sup>2</sup>/month



# Water

## Water consumption standard (l/person/day)

Description	BSRIA	Singapore (*)	Myanmar	TCVN 4513-1998	IHG	Accor
<b>Houses</b>						
Economic, local authority	120			100-150		
Medium, privately owned	120			150-200		
Luxury, privately owned	120			350-400		
<b>Flats</b>						
Economic, local authority	120	150	250	100-150		
Medium, privately owned	120	150	250	150-200		
Luxury, privately owned	120	150	250	350-400		
<b>Offices</b>						
Offices with canteen	45	45	49	10-15		
Offices without canteen	45	35		10-15		
<b>Hotels</b>						
2 star hotels	135	135		150-200		
5 star hotels	200		605 (l/guestroom)	250-300	560	550 (l/guestroom)

(\*) Handbook on Application for water supply  
 – Water supply Department Singapore

# Water

## Water consumption in HK

[http://www.wsd.gov.hk/en/education/water\\_conservation/calculation\\_of\\_per\\_capita\\_daily\\_water\\_consumption/index.html](http://www.wsd.gov.hk/en/education/water_conservation/calculation_of_per_capita_daily_water_consumption/index.html)



The screenshot shows the website for the Government of the Hong Kong Special Administrative Region, specifically the Water Conservation Home page. The page title is "Calculation of Per Capita Daily Water Consumption". The main content area provides information on the average water consumption per person per day in Hong Kong (0.13 cubic meter or 130 liters) and offers examples for calculating per capita daily water consumption. The example provided is "Example 1 - No change in the number of family members during the billing period".

Home > Education > Water Conservation > Calculation of Per Capita Daily Water Consumption

### Calculation of Per Capita Daily Water Consumption

Currently the average water consumption per person per day in Hong Kong is 0.13 cubic meter (i.e. 130 liters). You may make reference to the following examples for calculating the per capita daily water consumption of your family.

**Example 1 - No change in the number of family members during the billing period**

Average daily consumption of the billing period given on bill = 0.455 cu m

Number of members in your family = 4


Per capita daily water consumption of your family is  
= 0.455 cu m / 4  
= 0.114 cu m

# Water

## Water consumption in Singapore

<https://www.pub.gov.sg/watersupply/singaporewaterstory>

**Per Capita Household Water Consumption**  
(litres per person per day)



## Water

Water consumption – In DaNang - Vietnam

[http://www.iges.or.jp/files/research/scp/PDF/20151118/4\\_Nguyen\\_Mai.pdf](http://www.iges.or.jp/files/research/scp/PDF/20151118/4_Nguyen_Mai.pdf)

### IV. CONCLUSIONS AND RECOMMENDATIONS

#### 1. Conclusions

##### \* Water supply

- The percentage of households, public buildings used tap water is high >95%.

- Average water use depends on the level of appliances and water use habits. Average water use counted for the whole city is 146 l/person/day.

- Most of data shows amount of water use in households and public buildings less than standard TCVN 33-2006, TCVN 4513-1988.

- Diagram of water supply that used in households is mostly the same, it is the water system with roof tank and in public buildings is Storage tank – Pum – Tank

##### \* Water drainage

- The percentage of wastewater connected to sewer network of the city is low. (<50%)

- Public buildings: the amount of sanitary equipment is still less than the demand.

## Water

Water consumption – From New Saigon Apartment (typical 3Bedroom Apart.)

No. of people: 4 persons

Water consumption per day: 117 l/p/d

**Tiền nước sử dụng tháng: 03/2016** (Water fee)

Có 04 nhân khẩu được sử dụng trong định mức. Chi tiết nh

Chỉ số cũ (Previous No)	Chỉ số mới (Present No)	Lượng nước (m <sup>3</sup> )	Đơn giá (đ/m <sup>3</sup> ) (Đã bao gồm VAT 5%)
<b>01043</b>	<b>01057</b>	14	
Định mức 1 (First level)		14	5,565
Định mức 2 (Second level)		-	10,710
Ngoài định mức (Out of level)		-	11,970
<b>Tổng cộng tiền nước (Total)</b>			

Quý khách hàng còn nợ các khoản tính đến ngày 31/03  
(The debts of last month)



# Water Quality

Parameter	WHO Standards	EU Standards	CIBSE	QCVN 1:2009/BY T	IHG Desirable Levels
pH	6.5-9.2	6.5-8.5	5.5-9.5	6.5-8.5	7-8
Conductivity (mS/m)	-	400	150	-	400
Chlorides	250	250	400	250	<50
Sulphates	200	250	250	250	<250
Hardness (ass CaCO3)	-	100		300	<100
Magnesium	-	50	50	-	<50
Sodium	250	175	-	200	<50
Potassium	-	12	12	-	<12
Aluminium	-	0.2	0.2	0.2	<0.2
Total Dissolved Solids (TDS)	1000	1500		1000	<500
Nitrates	45	50	50	50	0
Nitrites	-	0.1	0.1	3	0
Ammonium	-	0.5	0.5	3	<0.5
Phenols	0.001	0.0002	0.0002	0.001	0
Organic Chlorine Compounds	-	0.025	-		0
Pesticides	-	0.0001	0.005		0
Iron	0.3	0.2	0.2	0.3	<0.2
Manganese	0.05	0.05	0.05	0.3	<0.05
Copper	0.05	0.05	3	1	<0.05
Zinc	5	0.1	5	3	<0.1
Lead	0.5	0.04	0.5	0.01	0
Cadmium	0.01	0.005	0.005	0.003	0
Total Coliform (bacteria/100ml)	0	0	0	0	0
Total Ecoli (bacteria/100ml)	0	0	0	0	0

Potable water quality standard (ppm) or (mg/l)



## Water Quality

Parameter	City water supply in HCM (From BOO Thu Duc Oct 11 <sup>th</sup> , 2016)	WHO Standards	QCVN 1:2009/BYT
pH	6.6	6.5-9.2	6.5-8.5
Conductivity (mS/m)		-	-
Chlorides	8	250	250
Sulphates	17	200	250
Hardness (ass CaCO <sub>3</sub> )	22	-	300
Sodium	1.32	250	200
Aluminium	0.53	-	0.2
Total Dissolved Solids (TDS)	80	1000	1000
Nitrates	1.39	45	50
Nitrites	0.039	-	3
Ammonium	0.04	-	3
Phenols	<0.001	0.001	0.001
Pesticides		-	
Iron	0.853	0.3	0.3
Manganese	0.0361	0.05	0.3
Copper	0.00548	0.05	1
Zinc	0.0199	5	3
Lead	0.001	0.5	0.01
Cadmium	<0.0004	0.01	0.003
Total coliform	0	0	0

City water quality in HCMC (ppm) or (mg/l)

Source: <http://sawaco.com.vn/>

## Water Quality HCMC

However, water quality in HCMC is not stable because of:

- Pollution of source water from river




*trash from the Nhieu Loc-Thi Nghe, the biggest canal in Ho Chi Minh City. Photo credit: Quang Dinh/Tuoi Tre*

- The old piping system



# Water Treatment




Water quality after sand filtration and UV disinfection

# Water Quality KPI

- Mains water is usually OK, but has slugs of bad water ...
- Water treatment requirements are modest
- Maintenance is the problem ... and regular testing regime required.
- Test & commission to verify
- Water KPI – Zero total coliforms, and trust in management!

Water Quality Parameter	Standard	Actual	Compliance	Notes
Total Coliforms (CFU/100ml)	0	0	100%	
Faecal Coliforms (FCU/100ml)	0	0	100%	
Free Chlorine (mg/L)	0.2 - 0.5	0.3	100%	
pH	7.0 - 8.5	7.5	100%	
Hardness (mg/L)	< 500	150	100%	
Iron (mg/L)	< 0.3	0.1	100%	
Manganese (mg/L)	< 0.1	0.05	100%	
Lead (mg/L)	< 0.01	0.005	100%	
Copper (mg/L)	< 0.05	0.02	100%	
Nitrate (mg/L)	< 50	10	100%	
Nitrite (mg/L)	< 0.1	0.05	100%	
Ammonia (mg/L)	< 0.5	0.1	100%	
Chlorophyll a (mg/L)	< 0.1	0.05	100%	
Chlorophyll b (mg/L)	< 0.1	0.05	100%	
Chlorophyll c (mg/L)	< 0.1	0.05	100%	
Chlorophyll d (mg/L)	< 0.1	0.05	100%	
Chlorophyll e (mg/L)	< 0.1	0.05	100%	
Chlorophyll f (mg/L)	< 0.1	0.05	100%	
Chlorophyll g (mg/L)	< 0.1	0.05	100%	
Chlorophyll h (mg/L)	< 0.1	0.05	100%	
Chlorophyll i (mg/L)	< 0.1	0.05	100%	
Chlorophyll j (mg/L)	< 0.1	0.05	100%	
Chlorophyll k (mg/L)	< 0.1	0.05	100%	
Chlorophyll l (mg/L)	< 0.1	0.05	100%	
Chlorophyll m (mg/L)	< 0.1	0.05	100%	
Chlorophyll n (mg/L)	< 0.1	0.05	100%	
Chlorophyll o (mg/L)	< 0.1	0.05	100%	
Chlorophyll p (mg/L)	< 0.1	0.05	100%	
Chlorophyll q (mg/L)	< 0.1	0.05	100%	
Chlorophyll r (mg/L)	< 0.1	0.05	100%	
Chlorophyll s (mg/L)	< 0.1	0.05	100%	
Chlorophyll t (mg/L)	< 0.1	0.05	100%	
Chlorophyll u (mg/L)	< 0.1	0.05	100%	
Chlorophyll v (mg/L)	< 0.1	0.05	100%	
Chlorophyll w (mg/L)	< 0.1	0.05	100%	
Chlorophyll x (mg/L)	< 0.1	0.05	100%	
Chlorophyll y (mg/L)	< 0.1	0.05	100%	
Chlorophyll z (mg/L)	< 0.1	0.05	100%	



**Coliform bacteria (total coliforms)**

- The term "coliform bacteria" refers to a vaguely defined group of Gram-negative bacteria which have a long history in water quality assessment.
- Coliform bacteria are microorganisms that primarily originate in the intestines of warm-blooded animals.
- Some of the bacteria included in this group are almost exclusively of faecal origin, while other members may also replicate in suitable water environments.
- The primary purpose of coliform tests is not to detect faecal pollution but to assess the general sanitary quality of treated drinking-water supplies.






Figure 10 Bacteriological compliance in distribution systems

# Light

**Table 2.12. Mandatory requirements for lighting power density (LPD)**

Type of building	LPD (W/m <sup>2</sup> )
Offices	11
Hotels	11
Hospitals	13
Schools	13
Commercial and services buildings	16
Apartments	8
Enclosed, in-house, basement car parks	3
Outdoor or open (roofed only) car parks	1.6

LPD from QCVN09-2013



**Energy lighting consumption**

**TABLE 7.1  
CIE LAMP COLOUR APPEARANCE GROUPS**

Colour appearance group	Colour appearance	Correlated colour temperature, K
1	warm	<3300
2	intermediate	3300≤5300
3	cool	>5300


NOTE: The term 'cool' used throughout this document equates to the colour appearance range designated 'cold' in ISO 8995/CIE S008/E.

**Lamp Color Temperature**

## Light

### Illumination level

Office – Screen based tasks, AS 1680.2 - 320lx




**Trends are for lower levels of ambient lighting for better environmental performance**


## Light – Color rendering Index - CRI 80, - LED's offer excellent CRI's



## Glare index – Office lighting for screen based tasks Maximum index 16.



# Light – Typical Calculation – Pearl Plaza Office



## Calculation Summary

Label	CalcType	Units	Avg	Max	Min	Avg/Min
Kitchen Workplane	Illuminance	Lux	516.31	632	354	1.46
Lobby Workplane	Illuminance	Lux	607.86	702	436	1.40




## Light – Typical Installation

600x600  
LED tube



LED Wall  
washer  
downlight



LED Panel




LED Panel with AC slot



# Light KPI

- Market has arrived at LED 100% ...
- Quality and lifecycle vary
- First cost is rapidly reducing.
- Test & commission to verify
- Light KPI – 8 W/m<sup>2</sup>, 110 lumens/W, 90 CRI, 2700 K

State	Province	City	Year	Sample No.	Sample Date	Sample Time	Sample Location	Sample Type	Sample No.	Sample Date	Sample Time	Sample Location	Sample Type	Sample No.	Sample Date	Sample Time	Sample Location	Sample Type
INDONESIA	JAWA BARAT	BANDUNG	2010	1	2010-01-01	08:00	Bandung City	Tap Water	1	2010-01-01	08:00	Bandung City	Tap Water	1	2010-01-01	08:00	Bandung City	Tap Water



**Coliform bacteria (total coliforms)**

- The term "coliform bacteria" refers to a vaguely defined group of Gram-negative bacteria which have a long history in water quality assessment.
- Coliform bacteria are microorganisms that primarily originate in the intestines of warm-blooded animals.
- Some of the bacteria included in this group are almost exclusively of faecal origin, while other members may also replicate in suitable water environments.
- The primary purpose of coliform tests is not to detect faecal pollution but to assess the general sanitary quality of treated drinking-water supplies.







Figure 10 Bacteriological compliance in distribution systems

# Lifts

- CIBSE Guidelines

**Table 3.7** Probable quality of service in office buildings

Interval (s)	Quality of service
<20	Excellent
25	Above average
30	Average
40	Below average
>50	Unsatisfactory



**Figure 3.1** Passenger demand pattern showing four distinct classical passenger demands

# Lifts

## Key parameters

- quantity,
- speed,
- capacity,
- controls.
- occupant density

Lift [m]	Travel	Rated speed [m/s]	Acceleration [m/s <sup>2</sup> ]	Single floor flight time [s]
20		1.0	0.4-0.7	7
32		1.6	0.7-0.8	6
50		2.5	0.8-0.9	5.5
63		3.0	1.0	5.0
100		5.0	1.2	4.5
120		6.0	1.2	4.5
>120		>6.0	1.2	4.5




## Lifts

- Building population density by region
- For Vietnam, we typically use 10 to 14 msq per person for mixed use commercial office buildings


### Building Space per Person Commercial Square Feet in 2007

Source: World Business Council for Sustainable Development




## Lifts

- Building population density by industry (US data)



# Lifts KPI

- Consider whether 'beating the market' or 'achieving acceptable standards' is your aim.
- Ensure sufficient number of lifts
- Ensure sufficient capacity (function of floorplate)
- Ensure lift speed (function of lift height)
- Ensure appropriate zoning and controls.
- For offices should really be looking for an interval of 30 to 40 seconds... using expected occupancy.

**WHAT Does KPI Mean?**

**KEY-PERFORMANCE-INDICATOR-** (IMPORTANT / RELEVANT)  
(DOING, Carrying Out, Executing)  
(POINT OUT, TELL, SHOW)

**K<sup>ON</sup>CERN-S<sup>Y</sup>IGNAL-** (WHAT AFFECTS RESULTS)  
(WHAT RESULT ARE INTENDED)  
(INDICATE DIRECTION)

KPI is a formula to collect information that is useful to your management team. Performance leads to success.

# Internet





## Internet

- Performance requirements vary depending on task

Applications	Minimum Bandwidth	Latency Tolerance
Login to central server (authentication, download profiles, etc.)	< 1 Mbps	Low
Web access	< 1 Mbps	Medium
Email	< 1 Mbps	High
Streaming video	From 1 Mbps to 20 Mbps (High Definition)	Low – Medium
Classroom management	< 1 Mbps	Medium

Table 1 - Common Applications

# How Much Internet Bandwidth Does Your Business Need?

## No Data? Follow the Education Sector

Broadband Access for Teaching, Learning, and School Operations	2014-15 School Year Target	2017-18 School Year Target
An external Internet connection to the Internet service provider (ISP)	At least 100 Mbps per 1,000 students/staff	At least 1 Gbps per 1,000 students/staff
Internal wide area network (WAN) connections from the district to each school and among schools within the district	At least 1 Gbps per 1,000 students/staff	At least 10 Gbps per 1,000 students/staff

## Internet

# Guests Are Winning the Battle Over Hotel Bandwidth

Hotel guests are devouring hotel bandwidth with increasing demands, The majority of guests now travel with 3x devices

- 1 to 2 Mbps per guest room is current
- Typically a 1Gbps connection to the hotel site is minimum
- Band-width requirements projected to increase 4-fold over 5 years globally

## Internet KPI

- Fiber to the .... FTTX
- Multiple vendors
- Subscribe Diamond package(s)
- Speed.... 1 Gbps for hotel, 100 Mbps for office, (10 Mbps for home)



### INTERNET PERFORMANCE



↑ MONITOR | ⚙️ CONTROL | 📊 OPTIMIZE



# People

- Different people densities for architectural planning, lifts, ACMV, water etc
- Occupancy varies throughout the day
- Occupancy varies over the life of a building.
- Should be aware that performance will vary significantly with occupancy.
- Lifts may only be sized for 12 m<sup>2</sup>/p while occupancies will approach 6 m<sup>2</sup>/p, and that will likely remain a disconnect, increasing lift waiting times from 40 seconds to > 100 seconds.

Activity	Typical Application	Heat Gain / Person (q <sub>p</sub> )	LHG (q <sub>l</sub> )
Seated at rest	Theater	245	105
Seated, light work	Office	245	155
Moderate office work	Office	250	200
Standing, walking slowly	Retail Sales	250	250
Light bench work	Factory	275	475
Dancing	Nightclub	305	545
Heavy work	Factory	580	870



Level of Activity	Typical Application	Heat Gain / Person (q <sub>p</sub> )	LHG (q <sub>l</sub> )
Seated at rest	Theater	245	105
Seated, light work	Office	245	155
Moderate office work	Office	250	200
Standing, walking slowly	Retail Sales	250	250
Light bench work	Factory	275	475
Dancing	Nightclub	305	545
Heavy work	Factory	580	870

Level of Activity	Typical Application	Heat Gain / Person (q <sub>p</sub> )	LHG (q <sub>l</sub> )
Seated at rest	Theater	245	105
Seated, light work	Office	245	155
Moderate office work	Office	250	200
Standing, walking slowly	Retail Sales	250	250
Light bench work	Factory	275	475
Dancing	Nightclub	305	545
Heavy work	Factory	580	870

Occupant density (ppl/m <sup>2</sup> )	Number of people (ppl)
0.1	40
0.2	80
0.5	200
1.0	400
1.3	520



Arrive Sequence	1	2	3	4	7	5	6	8
Expected	1	2	3	4	5	6	7	8
Buffer-occupancy	0	0	0	0	1	1	0	0
RBD[0] = 6/8, RBD[1] = 2/8								



## Summary


	KPI	Measure	Unit
Air Quality	AQI	50 to 100	(index)
Energy	ESD	150 - 170	kWh/m <sup>2</sup> /a
Water	ESD	150 residential 35 office	l/p/d
Water Quality	Health	0	Total Coliforms
Light	Comfort	8 110 90	W/m <sup>2</sup> Lumens/W CRI
Lifts	Interval	30 to 40	seconds
Internet	Speed	100 office 1 hotel	Mbps Gbps
People	Density	10	m <sup>2</sup> /p

# WINE & ENGINEERING CONNECTIONS

THURSDAY  
5pm



Indochine Engineering Vietnam Ltd.,  
Unit 12-01 Pearl Plaza  
561A Dien Bien Phu Street  
Binh Thanh District, HCMC, VN  
Tel: (848) 6290 9400



BRING YOUR QUESTIONS ALONG AND TALK TO AN ENGINEER

**THANK YOU**